



Invitation for Bids for La Plaza Terminal Dome Repair for the City of Brownsville B-Metro Department

BID # LPD-61-1017

Addendum # 1

August 30, 2017 at 3:00 P.M.

City of Brownsville
Purchasing Department

ADDENDUM # 1

**Invitation for Bids for La Plaza Terminal Dome
Repair for the City of Brownsville B-Metro
Department
BID # LPD-61-1017**

ACKNOWLEDGEMENT OF RECEIPT

Please fax this page upon receipt

Please fill in the requested information below as acknowledgment that *you have received the* Addendum noted above. If your firm is interested in participating, this sheet must be completed and returned or faxed to:

Mr. Roberto C. Luna, Jr.
Purchasing Director - City of Brownsville - P.O. Box 911
City Hall 1001 E. Elizabeth St. 1ST FLOOR Suite No. 101
Brownsville, Texas 78520
Phone: (956) 548-6087 Fax: (956) 546-2711
Email: purchasing@cob.us

Name of Firm: _____

Address: _____

City, State _____ Zip: _____

Telephone Number: _____ Fax Number: _____

E-mail: _____

() **YES**, Our Company does have an interest in responding.

() **NO**, Our Company does not have an interest in responding.

Name: (Print) _____

Title: _____

Signature: _____

Date: _____



Invitation for Bids for La Plaza Terminal Dome Repair for the City of Brownsville B-Metro Department

BID # LPD-61-1017

Addendum # 1

August 30, 2017 at 3:00 P.M.

ADDENDA: The undersigned hereby acknowledges receipt of the following addenda to the Specifications, all of the provisions and requirements of which Addenda have been taken into consideration in the preparation of the foregoing proposal.

1. Clarifications/Additional Information/Changes to the Original bid package:

This Addendum is issued to Clarify questions and modify plans and Specifications. These changes become part of the plans and specifications to be included in the Proposal Documents.

1. General Contractor to have experience in projects with Municipal City, State, County and School districts and provide 3 Project References and Administrative Personnel contact information for referrals on projects the General Contractor has worked on.
2. Contractor to have experience installing dome, steeples and or other building components by crane. Subcontractor operating crane to have 5 years experience installing building components over 50 ft above ground. Provide References to Projects which required installation of equipment and/or building components at heights above 50 ft
3. Provide 20 gauge gutter with connection edge for led light fixtures - brace as required.
4. Install continuous leaf guard on gutter - brace as required.
5. On flat area of octagon below dome provide nixlite bird screen.
6. Coordinate dome shop drawings and installation of new dome with existing dome structure steel.
7. When installing dome, contractor to minimize blocking street traffic preferably for two days maximum. Keeping one lane open shall be preferred. Coordinate with and follow instructions from City of Brownsville traffic department. All costs for street closing, baracades, traffic control and security costs to be included in the cost for construction as part of the Base Bid.

Submitted,

(Name of Bidder)

(Signature)

(Print)

Date

End of Addendum # 1